



# 太阳能产品认证证书

证书编号: CQC14024115243

### 申请人名称及地址

宁波锦浪新能源科技有限公司  
浙江省象山县经济开发区滨海工业园金通路57号

### 制造商名称及地址

宁波锦浪新能源科技有限公司  
浙江省象山县经济开发区滨海工业园金通路57号

### 生产企业名称及地址

宁波锦浪新能源科技有限公司 (V017008)  
浙江省宁波市象山县经济开发区滨海工业区金通路57号

### 产品名称和系列、规格、型号

光伏并网逆变器

见附件

### 产品标准和技术要求

NB/T32004-2013(IIIa, 不含低电压穿越试验)

### 认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC33-461239-2013认证规则的要求, 特发此证。

发证日期: 2014年09月03日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持



主任:



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

T 0002488



## SOLAR PRODUCT CERTIFICATE

No.: CQC14024115243

### NAME AND ADDRESS OF THE APPLICANT

Ningbo Ginlong Technologies Co., Ltd.  
No.57, Jintong Road, Binhai industrial park, Xiangshan, Ningbo, Zhejiang, P.R.China

### NAME AND ADDRESS OF THE MANUFACTURER

Ningbo Ginlong Technologies Co., Ltd.  
No.57, Jintong Road, Binhai industrial park, Xiangshan, Ningbo, Zhejiang, P.R.China

### NAME AND ADDRESS OF THE FACTORY

Ningbo Ginlong Technologies Co., Ltd.(V017008)  
No.57, Jintong Road, Binhai industrial park, Xiangshan, Ningbo, Zhejiang, P.R.China

### NAME, MODEL AND SPECIFICATION

PV Grid-connected Inverter  
See Appendix

### THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

NB/T32004-2013(IIIa, Without Low Voltage Ride Through Test)

### CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules CQC33-461239-2013.

Date of issue: Sep.03,2014

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.



President:

A handwritten signature in black ink, appearing to read "Wang Kejiao".

Wang Kejiao



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

T 0002488





# 太阳能产品认证证书

附录:

第 1 页 共 1 页

证书编号: CQC14024115243

纸号: 2488

GCI-6K

直流输入: 最大功率电压跟踪范围 250V-800Vdc, 最大直流输入电压 1000Vdc,  
最大输入电流 15A/15A;

交流输出: 3~, 380V, 50Hz, 10.5A, 额定交流输出功率 6kW.

GCI-10K

直流输入: 最大功率电压跟踪范围 300V-800Vdc, 最大直流输入电压 1000Vdc,  
最大输入电流 15A/15A;

交流输出: 3~, 380V, 50Hz, 16A, 额定交流输出功率 10kW.

GCI-15K

直流输入: 最大功率电压跟踪范围 300V-800Vdc, 最大直流输入电压 1000Vdc,  
最大输入电流 18A/18A;

交流输出: 3~, 380V, 50Hz, 24A, 额定交流输出功率 15kW.

注: 此附录与证书同时使用时有效。



主任: \_\_\_\_\_

A handwritten signature in black ink, written over a horizontal line.



## 中国质量认证中心

中国 北京 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>